



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.008/94/1

Expires: 29 October 2013

BULKHEAD PANELS

BNZ MATERIALS, INC
400 Iron Horse Park
N. Billerica MA 01862

"Marinite M" calcium silicate panel approved as meeting Class B-15 requirements in 3/4 inch thickness and nominal density of 46 lb/ft³ (736 kg/m³).

May be used as a component of Class A-60 construction.

Identifying Data: NBS Report FR3951, Underwriters Laboratories, Inc. Test Report 78NK6360, File R7975-2 dated 14 September 1978; manufacturer's letter dated 27 September 1978; and BNZ drawing No. 107 (30 pages) dated 27 January 1989.

Follow-up Program: UL

Approval valid only for products from above manufacturing facility.


Supersedes and extends Appr. No. 164.008/94/1 dated 9 August 2004, and reflects change in address.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate. and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 29th DAY OF
OCTOBER 2008, AT WASHINGTON D.C.


K. J. HEINZ
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT